


Leakage distance, minimum, mm	559
Protected Leakage distance, minimum, mm	224
Dry - arcing distance, minimum, mm	241
Cantilever strength, kN	12.5
Cantilever proof load, kN	5
Low - frequency dry flashover, kV	110
Low - frequency wet flashover, kV	85
Critical - impulse flashover, positive, kV	180
Critical - impulse flashover, negative, kV	205
Low - frequency test voltage, rms to ground, kV	22
Maximum RIV at 1,000 kHz, radio freed, uV	100
Colour of insulator glazed	Brown

 บริษัท ผลิต วัสดุ ฉนวน ไฟฟ้า MANAGEABLE INSULATOR CO., LTD.	INSULATOR, LINE - POST TYPE, ACCORDING TO ANSI C 29.7 CLASS 57 - 2 L / TIS 1077, TYPE 57 - 2		CATALOGUE NO. LP - 572
	SCALE : NTS.	UNIT: mm.	ISSUE :
MANAGEABLE INSULATOR COMPANY			DRAWING NO. FAC - 001
			DATE: 2 / 12 / 2013
			DRAWN : <i>D.R.</i>

FAC



POWARC 10KA, 0.4 SEC.
3KA, 0.65 SEC.

THAILAND
YEAR

TIS.1077 - 2535

บริษัท ผลิตไฟฟ้า คุรุภัณฑ์ จำกัด
MANAGEABLE
INSULATOR CO.,LTD.
MAN

MARKING ON INSULATOR LINE - POST TIS. 1077 TYPE 57 - 2

CATALOGUE NO. LP - 572

SCALE : NTS. UNIT:

ISSUE :

DRAWN : *Sin*

APPROVED : *enaf*

MANAGEABLE INSULATOR COMPANY

DATE: 17 / 3 / 2015

DRAWING NO. FAC - 010-1