

Leakage distance, minimum, mm	559
Protected Leakage distance, minimum, mm	224
Dry - arcing distance, minimum, mm	241
Cantilever strength, kN	12.5
Cantilever proof load, kN	5
Low - frequency dry flashover, kV	110
Low - frequency wet flashover, kV	85
Critical - impulse flashover, positive, kV	180
Critical - impulse flashover, negative, kV	205
Low - frequency test voltage, rms to ground, kV	22
Maximum RIV at 1,000 kHz, radio freed, uV	100
Colour of insulator glazed	Brown

บริษัท ผลิต วัสดุ วัสดุ ผลิต
MANAGEABLE
INSULATOR CO., LTD.
MAN

INSULATOR, LINE - POST TYPE, ACCORDING TO ANSI C 29.7 CLASS 57 - 2 L / TIS 1077, TYPE 57 - 2

SCALE : NTS. UNIT: mm. ISSUE : DRAWN : *D.R.* APPROVED : *enr*

MANAGEABLE INSULATOR COMPANY DATE: 2 / 12 / 2013 DRAWING NO. FAC - 001

CATALOGUE NO. LP - 572

FAC





POWARC 10KA, 0.4 SEC.
3KA, 0.65 SEC.

THAILAND
YEAR

TIS.1077 - 2535

บริษัท ผลิตไฟฟ้า คุรุภัณฑ์ จำกัด
MANAGEABLE
INSULATOR CO.,LTD.
MAN

MARKING ON INSULATOR LINE - POST TIS. 1077 TYPE 57 - 2		CATALOGUE NO. LP - 572		
SCALE : NTS.	UNIT :	ISSUE :	DRAWN : 	APPROVED : 
MANAGEABLE INSULATOR COMPANY		DATE: 17 / 3 / 2015	DRAWING NO. FAC - 010-1	