



Leakage distance, minimum, mm	737
Dry - arcing distance, minimum, mm	311
Cantilever strength, kN	12.5
Cantilever proof load, kN	5
Low - frequency dry flashover, Kilovolts	125
Low - frequency wet flashover, Kilovolts	100
Critical - impulse flashover, positive, Kilovolts	210
Critical - impulse flashover, negative, Kilovolts	260
Low - frequency test voltage, rms to ground, Kilovolts	30
Maximum RIV at 1,000 kHz, microvolts	200
Colour of insulator glazed	Brown

INSULATOR, LINE - POST TYPE, ACCORDING TO TIS. 1077 TYPE 57 - 3

CATALOGUE NO. LP - 573

SCALE : NTS.

UNIT: mm.

ISSUE :

DRAWN :

D.S.

APPROVED :

MAN

MANAGEABLE INSULATOR COMPANY

DATE: 2 / 12 / 2013

DRAWING NO. FAC - 016

FAC



THAILAND YEAR

TIS. 1077 - 2535

บริษัท یمان یمان จำกัด
MANAGEABLE
INSULATOR CO., LTD.
MAN

MARKING ON LINE - POST INSULATOR ANSI CLASS 57 - 3 / TIS 1077

SCALE : NTS. UNIT:

ISSUE :

DRAWN : *DM*

MANAGEABLE INSULATOR COMPANY

DATE: 17 / 3 / 2015

CATALOGUE NO. LP-573

APPROVED : *enif*

DRAWING NO. FAC - 027-1