



Leakage distance, mm	953
Protected Leakage distance (mm)	483
Cantilever strength, kN	12.5
Cantilever proof load, kN	5
Low - frequency dry flashover, kilovolts	140
Low - frequency wet flashover, kilovolts	95
Critical - impulse flashover, positive, kilovolts	225
Critical - impulse flashover, negative, kilovolts	300
Low - frequency test voltage, rms to ground, kilovolts	44
Maximum RIV at 1,000 kHz, microvolts	200
Puncture proof	Yes
Colour of insulator glazed	Brown

INSULATOR, PIN - POST TYPE ACCORDING TO TIS. 1251, TYPE 56 / 57 - 4

SCALE : NTS. UNIT: mm.

ISSUE :

DRAWN : *DSR*

APPROVED : *DSR*

MANAGEABLE INSULATOR COMPANY

DATE: 2 / 12 / 2013

DRAWING NO. FAC - 015

CATALOGUE NO. PP - 574

FAC

THAILAND



TIS.1251 - 2537

YEAR

POWARC 10KA, 0.4 SEC.
3KA, 0.79 SEC.



MARKING ON INSULATOR PIN - POST TIS 1251 - 2537 CLASS 56 / 57 - 4

CATALOGUE NO. PP-574

SCALE : NTS. UNIT:

ISSUE :

DRAWN : *Sin*

APPROVED : *อนรรักษ์*

MANAGEABLE INSULATOR COMPANY

DATE: 17 / 3 / 2015

DRAWING NO. FAC - 031-2